CERTIFICATE



of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50419893 0001

Report No.:

50188199 001

Holder:

GLOBAL LYNX CORPORATION LIMITED

FLAT/RM1004 10/F BANK OF AMERICA TOWER 12

HARCOURT ROAD CENTRAL HK

Product:

Emergency Illumination Device (LED Emergency Luminaire)

Identification:

72-102/LED/5W/75K

Serial No.: n.a.

Remark: Refer to test report 50188199 001 for details. Tested acc. to: EN 60598-1:2015 EN 60598-2-22:2014

EN 62471:2008 EN 60598-2-2:2012

Ш

EN 62493:2015

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Aheinland LGA Aroo

er Guoping Zheng

Date 12.01.2024

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

The CE marking may be used if all relevant and effective EC Directives are complied with. ()